Maximum Power Point Tracker Using Fuzzy Logic Controller with Reduced Rules

Adel Haddouche¹, Mohammed Kara², Lotfi Farah³

^{1,2}Department of Mine Engineering, University Larbi tebessi Tebessa, Algeria
³Génie Electromécanique Laboratory Department of Mine Engineering, University Badji Mokhtar Annaba, Algeria

Article Info	ABSTRACT		
Article history:	This paper presents a fuzzy logic controller for maximum power point		
Received Feb 10, 2018	tracking (MPPT) in photovoltaic system with reduced number of rules instead of conventional 25 rules to make the system lighter which will		
Revised Jul 20, 2018	improve the tracking speed and reduce the static error, engendering a global		
Accepted Aug 6, 2018	performance improvements. in this work the proposed system use the power		
	variation and current variation as inputs to simplify the calculation, the		
Keyword:	introduced controller is connected to a conventional grid and simulated with MATLAB/SIMULINK. The simulation results shows a promising indication		
High efficiency	to adopt the introduced controller as an a good alternative to traditional		
Maximum power point tracking	MPPT system for further practical applications.		
PV systems			
Reduced fuzzy logic			

Copyright © 2018 Institute of Advanced Engineering and Science. All rights reserved.

Corresponding Author:

Adel Haddouche, Department of Mine Engineering, Larbi Tebessi University, Tebessa Algeria Email: adelhaddouche@yahoo.fr

1. INTRODUCTION

During the last years, urgent needs for a new energy alternative in order to overcome the energy crisis and global warming issues. Those problems have significantly promoted the development of renewable energies. In this context, the photovoltaic systems represent a very competitive solution. Unfortunately, this solution is not perfect due to low energy conversion efficiency, and to overcome this problem it's necessary to provide the PV system with an MPPT controller to gather the maximum electrical power from the photovoltaic modules under different working conditions. Therefore, Many methods of MPPT were completed in previous studies, as perturb and observe (P&O) [1], fractional open-circuit voltage [2], fractional short-circuit current, incremental [2] conductance (IncCon), line approximation, ripple correlation control (RCC), PID control, fuzzy logic control (FLC)[1], genetic algorithm[3], neural network and neuro-fuzzy approaches [4]. On the other hand, intelligent systems like FLC, neural network, and neuro-fuzzy systems are able to determine their parameters and are capable of operating under the highly nonlinear system. As a result, the FLC-based MPPT algorithm attracts many research interests. Recently in literature, numerous MPPT techniques based on these techniques have been proposed [1-6]. In comparison with the P&O algorithm, they provide superior tracking performance. However, the design consideration and realization complexity for different kinds of intelligent based MPPT techniques vary widely.

Regarding the design of input/output membership functions (MFs), it is known that the input/output MFs design has a great impact on FLCs' performance in terms of tracking time. In order to deal with this issue, genetic algorithm (GA)[7], particle swarm optimization (PSO)[8] and artificial neural network (ANN)[9] are proposed in the literature to optimize the FLC MFs. In this work, we propose an MPPT based on fuzzy logic with a reduced number of rules instead of the traditional high number of rules. The goal of this reduction is to make the whole system lighter and more reactive in order to improve global performance

especially tracking time and to offer a low cost, high efficiency FLC-based MPPT algorithm, with power variation (Δ Ppv) and output current variation (Δ Ipv) as the inputs of the proposed FLC. The design of the FLC scheme and rule table with results will be introduced later in this paper.

2. MAXIMUM PERFORMANCE POINT TRACKER OPERATION PRINCIPLE

The connected load characteristics have an important influence on the photovoltaic operating behavior as shown in Figure 1, [10, 11]. Indeed, for a load, with an internal resistance Ri, the optimal adaptation occurs only at a particular operating point, referred to as the maximum power point (MPP) and noted in our case P max, as shown in Figure 2. Thus, when a direct connection is made between the source and the load, the output of the PV module is rarely maximum and the operating point is not optimal. To remedy this problem, it is necessary to add an MPPT controller with a DC-DC converter, between the source and the load, as shown in Figure 3 [12]. the characteristics of a PV system vary with temperature and irradiance, as shown in Figure 4, and 5 [13,14]. Therefore, an MPPT controller is also required to track the new modified maximum power point in its corresponding curve whenever a variation in temperature and/or irradiance occurs many MPPT control techniques have been conceived for this purpose in the last decades [15, 16]. They can be classified as:

- 1. Voltage feedback based methods, which compare the PV operating
- 2. Voltage with a reference voltage in order to generate the PWM control signal to be applied to the DC-DC converter [17].
- 3. Current feedback based methods that use the PV module
- 4. Short circuit current as a feedback in order to estimate the optimal current corresponding to the maximum




Figure 1.Current-voltage characteristic of a PV module




Figure 2. P-v characteristic of a PV module

Figure 3. Photovoltaic system




Figure. 4. Influence of the solar radiation for constant temperature




Figure 5.The boost DC-DC converter circuit

3. DC-DC CONVERTER

In order to always ensure the operation point on the maximum power point, or close to it, specific circuit, called Maximum Power Point Tracker (MPPT), is employed. Usually, the MPPT is achieved by interposing a power converter (DC-DC converter) between the PV generator and the load (battery), thus, acting on the converter duty cycle (D) it is possible to guarantee the operation point as being the MPP [18], Figure 4 shows the circuit of the buck converter, whose output voltage (Vb) is less than or equal to the input voltage Vi (PV generator voltage).

A boost converter (step-up converter) is a DC-to-DC power converter that steps up voltage (while stepping down current) from its input (supply) to its output (load). It is a class of switched-mode power supply (SMPS) containing at least two semiconductors (a diode and a transistor) and at least one energy storage element: a capacitor, inductor, or the two in combination. To reduce voltage ripple, filters made of capacitors (sometimes in combination with inductors) are normally added to such a converter's output (load-side filter) and input (supply-side filter). [20]. the boost converter can come from any suitable DC sources, such as batteries, solar panels, rectifiers and DC generators. A process that changes one DC voltage to a different DC voltage is called DC-to-DC conversion. A boost converter is a DC-to-DC converter with an output voltage greater than the source voltage. A boost converter is sometimes called a step-up converter since it "steps up" the source voltage. Since power (P=VI) must be conserved, the output current is lower than the source current. The dynamic model of the used boost converter as shown in Figure 4.

4. FUZZY LOGIC MPPT CONTROLLER

Fuzzy logic controllers have been introduced in the tracking of the MPP in PV systems [12–14]. Due to their advantages and being robust and relatively simple to design since the knowledge of the exact model is not required. On the other hand, the designer needs complete knowledge of the PV system operation.

Maximum Power Point Tracker Using Fuzzy Logic Controller with Reduced Rules (Adel Haddouche)

In this paper, the inputs of the proposed MPPT controller are the power variation (Δ Ppv) and the current variation (Δ Ipv). The MFs of the utilized input and output variables for the proposed controller are illustrated in Figure 6 shows the MFs of the input variables; both Δ Ppv and Δ Ipv MFs are in triangular form. Fig.7 is the MF of the output (duty cycle step size D), which is also in triangular form. In (Fig.7), DP stands for power variation, DI represents current variation and D denotes duty cycle variation. For linguistic variables, P represents positive, N represents negative, B, S and Z are defined as big, small and zero, respectively. From Figure 6, each of the input variables Δ Ppv and Δ Ipv is mapped into five different linguistic values. Instead usual proposed fuzzy system our model proposes a limited number of rules the fuzzy inference is carried out by using Mamdani's method, (Table 1), and the defuzzification uses the centre of gravity to compute the output of this FLC, which is the duty cycle, the control rules are indicated in Table 1. Figure 8 shows the structure of the fuzzy controller.




Figure 6. Membership functions for inputs (input1 DPv) (input2 DIv)





Figure 7. Membership function for output D (duty cycle)

Int J Pow Elec & Dri Syst, Vol. 9, No. 3, September 2018 : 1381 - 1389



System eren: 2 inputs, 1 outputs, 8 rules

Figure 8. The structure of the fuzzy controller

5. IMPLEMENTATION AND RESULTS

5.1. IMPLEMENTATION

The proposed FLC has been implemented and tested using SIMULINK (MATLAB) to a100-kW Grid-Connected PV Array as shown in Figure 11 (Detailed Model). A step change in solar radiation applied to assess the robustness of the proposed controller. Irradiation pattern is shown in Figure 9, for the PV model we chose the SUNPOWER SPR-305-WHT as shown in Figure 10.




Figure 9. Irradiation pattern




Figure 10. Array proprieties

Maximum Power Point Tracker Using Fuzzy Logic Controller with Reduced Rules (Adel Haddouche)




Figure 11. 100-kW grid-connected PV array

5.2. RESULTS

The simulation results of the PV generator output power as shown in Figure 12, operating voltage as shown in Figure 13, operating current as shown in Figure 14, and the duty ratio as shown in Figure 15 and grid voltage (Figure 16 using a boost converter under standard test conditions has shown that the proposed FLC controller shows better static error (1.62 kW so **1.62/100.71= 0.016%**) and less Tracking time error (less than 0.005s) comparing to conventional MPPT methods seen in previous research as shown in Table 2 [21].




Figure 12. Generator output power




Figure 13. Operating voltage




Figure 14. Grid currents




Figure 16. Grid voltage

Table 2. Comparison of Results				
	FLC	P&O	FLC with reduced rules	
Tracking time (Sec)	0.018s	0.015	0.005s	
Static error (%)	0.25%	0.74%	0.016%	

Maximum Power Point Tracker Using Fuzzy Logic Controller with Reduced Rules (Adel Haddouche)

6. CONCLUSION

This paper presents a different control strategy of MPPT for the PV system using the FLC with a reduced number of rules. Simulation results show that the proposed fuzzy can track the MPP faster when compared to the conventional FLC. In conclusion, the proposed MPPT using fuzzy logic with 8 rules can improve the performance of the system and had a better response than a conventional controller in terms of the maximum power tracking time and static error.

REFERENCES

- Mohamed Amine Abdourraziq and Mohamed Maaroufi(2017). Experimental Verification of the Main MPPT Techniques for Photovoltaic System. International Journal of Power Electronics and Drive Systems (IJPEDS), pp. 384 – 391
- [2] Shen, C.L.; Tsai, C.T. Double-linear approximation algorithm to achieve maximum-power-point tracking for photovoltaic arrays. Energies 2012, 5, 1982–1997.
- [3] Yau, H.T.; Wu, C.H. Comparison of extremum-seeking control techniques for maximum power point tracking in photovoltaic systems. Energies 2011, 4, 2180–2195.
- [4] Yaichi, M., Fellah, M. K., & Mammeri, A. (2014). A neural network based MPPT technique controller for photovoltaic pumping system. International Journal of Power Electronics and Drive Systems, 4(2), 241.
- [5] Ishaque, K.; Salam, Z. A review of maximum power point tracking techniques of PV system for uniform insolation and partial shading condition. Renew. Sustain. Energy Rev. 2013, 19, 475–488.
- [6] Femia, N.; Petrone, G.; Spagnuolo, G.; Vitelli, M. Optimization of perturb and observe maximum power point tracking method. IEEE Trans. Power Electron. 2005, 20, 963–973.
- [7] Pandey, A.; Dasgupta, N.; Mukerjee, A.K. High-performance algorithms for drift avoidance and fast tracking in solar mppt system. IEEE Trans. Energy Convers. 2008, 23, 681–689.
- [8] D'Souza, N.S.; Lopes, L.A.C.; Liu, X. Comparative study of variable size perturbation and observation maximum power point trackers for PV systems. Electr. Power Syst. Res. 2010, 80,296–305.
- [9] Abdelsalam, A.K.; Massoud, A.M.; Ahmed, S.; Enjeti, P.N. High-performance adaptive perturb and observe MPPT technique for photovoltaic-based microgrids. IEEE Trans. Power Electron.2011, 26, 1010–1021
- [10] Hassaine L. Modélisation et Simulation d'un Système de Conditionnement de Puissance pour la Poursuite de Puissance Maximale dans les Systèmes Photovoltaïques. Alegria: Me´moire de Magister, Ecole Nationale Polytechnique (ENP); Juin 2003.
- [11] Lu CF, Liu CC, Wu CJ. Dynamic modeling of battery energy storage system and application to power system stability. IEE Proceedings Generation, Transmission and Distribution July 1995;142(4):429–35
- [12] A. A. Siddik and M. Shangeetha, "Implimentation of Fuzzy Logic Controller in photovoltaic Power generation using Boost converter and Boost Inverter,"International Journal of Power Electronics and Drive System (IJPEDS), vol/issue: 2(3), pp. 249-256, 2012.
- [13] Jena, D.; Ramana, V.V. Modeling of a photovoltaic system for uniform and non-uniform irradiance: A critical review. Renew. Sustain. Energy Rev. 2015, 52, 400–417.
- [14] Gottschalg R, Rommel M, Ineld DG, Ryssel H. Comparison of different methods for the parameter determination of the solar cell's double exponential equation. In: 14th European photovoltaic science and engineering conference (PVSEC), Barcelona, Spain; 1997.
- [15] Salas V, Olias E, Barrado A, Lazaro A. Review of the maximum power point tracking algorithms for stand-alone photovoltaic systems. Solar Energy Materials & Solar Cells 2006;90:1555–78.
- [16] EsramT, Chapman PL. Comparison of photovoltaic array maximum power point tracking methods. IEEE Transactions on Energy Conversion June 2007;22(2).
- [17] Veerachary M, Senjyu T, Uezato K. Voltage-based maximum power point tracking control of PV systems. IEEE Transaction on Aerospace and Electronic Systems Jan 2002;38:262–70
- [18] Coelho RF, Concer FM, Martins D. A simplified analysis of DC-DC converters applied as maximum power point tracker in photovoltaic systems. 2nd IEEE International Symposium on Power Electronics for Distributed Generation Systems, 2010; pp.29-34.
- [19] Hua C, Shen C. Control of DC/DC converters for solar energy system with maximum power tracking. 23rd Int Conference on Industrial Electronics, Control and Instrumentation (IECON 97), 9-14 Nov 1997; pp.827-32.
- [20] Erickson RW, Maksimovic D. Fundamentals of power electronics. 2nd edition, New York: Kluwer Academic Publishers; 2001.
- [21] S. Narendiran, Sarat Kumar Sahoo, Raja Das. Control and Analysis of MPPT Techniques for Maximizing Power Extraction and Eliminating Oscillations in PV System, Narendiran S., et al. / International Energy Journal 16 (2016) 107-118

BIOGRAPHIES OF AUTHORS



Haddouche Adel born in Moscow on 23 January 1986. he received his master degree in robotics and industrial computing from University of badji Mokhtar Annaba Algeria in 2012, actually he is preparing his thesis in order to obtain a Ph.D. degree in university Larbi tebessi Tebessa Algeria. His current research interests include AI, Fuzzy System, Genetic algorithm, Neural Network, PSO and Photovoltaic modeling and control, energy conversion and power electronics. He has authored and co-authored different seminar papers.



Kara Mohammed born in Oued Zenati on 20 November 1959.he received his Ph.D. degree in electromechanical science from University of Badji Mokhtar Annaba Algeria in 2007. since 1989 he held lecturing positions at The Larbi Tebessi university. In 2007 he is graduated to Senior Lecturer at the same university, he held administrative positions within the university such as Head of Department (mines department) from 2009 to 2011 and Vice-Rector of Higher Education, Continuing Education and Diplomas from 2011 to 2016, nowadays he is a Vice-rector of higher education, first and second cycle of continuing education, diplomas and higher education in graduation. His current research interests include maintenance and industrial safety, Applied Automation And Industrial Diagnostic. Dr Kara authored and co-authored different seminar papers.



Farah Lotfi received the B.Eng. and Ph.D. degrees in Arabic hand written recognition from the University of BadjiMokhtar Annaba, Algeria, in 1995 and 2000, respectively. From 2000 to 2012, he was a Research Associate with the University of Cherif Messadia, Algeria. He is currently a Research with BadjiMokhtar University in GénieElectromécanique Laboratory, Annaba, Algeria. His current research interests include AI, Fuzzy System, Neural Network and Photovoltaic modeling and control, energy conversion and power electronics. He has authored and co-authored different seminar papers. Dr. Lotfi serves as a Reviewer for international journals in his research field, AI such as Journal of Computer ScienceUSA